

OFFICE USE ONLY: PERMIT # _____

PERM. PARCEL # _____

DATE: _____

FEE: \$150.00 + 1.50 tax = 151.50 + electrical

**APPLICATION FOR GARAGE PERMIT
CITY OF PARMA HEIGHTS**

Application is hereby made for PERMIT to erect a building as described in detail below at LOCATION given. The acceptance of the permit herein applied for shall constitute an agreement on the part of the undersigned to abide by all the conditions therein contained; and to comply with all ordinances of the City of Parma Heights and the laws of the State of Ohio relating to the work to be done thereunder and said agreement is a condition of said permit.

We agree to notify the Building Department to INSPECT:
GRADE SETTING BEFORE POURING FOUNDATION
FRAMING BEFORE COVERING
ROUGHED IN PLUMBING BEFORE COVERING
ELECTRICAL WIRING BEFORE COVERING
FINAL INSPECTION ON COMPLETION

OWNER _____
Name Address

PHONE # _____

CONTRACTOR _____

CONTRACTOR ADDRESS _____

CONTRACTOR PHONE # _____

ESTIMATED CONSTRUCTION COST \$ _____

Ordinance demands that you file with this application:

1. Two complete detailed Drawings of proposed Building (scale 1/2" - 1")
2. Plot Plan showing: Distance of this Building from Main Building; each sideline, rear line, all existing buildings on adjacent lots.

This Building is to be located at _____
House # Street

GARAGE SIZE _____ x _____

HEIGHT OF GARAGE _____

Continued on back....

Its relation to existing main building:

Separate From Attached Directly to Attached thru Breezeway

INTERIOR WALLS AND CEILING FIREPROOFED? YES NO

If attached, Connecting Door is SOLID WOOD METAL

ROOMS ABOVE GARAGE? _____

FRAMING ON

16" centers
 24" centers

FOOTINGS

Concrete

FOUNDATION

Block

SLAB

Concrete

EXTERIOR WALLS

Wood
 Brick

ROOF

Wood

ROOFING

Asphalt Shingle

ROOF STYLE

Gable

DOWNSPOUTS MUST BE TIED INTO STORM SEWER

ELECTRICAL PERMIT APPLICATION

BASE FEE: \$75.00

NUMBER OF SWITCHES, OUTLETS & LIGHTING FIXTURES _____ @ \$2.00 EACH =\$ _____

1% TAX= _____

Total Electric permit = \$ _____

ELECTRICAL CONTRACTOR _____

CONTRACTOR ADDRESS _____

CONTRACTOR PHONE # _____

Signature of Owner/Contractor

Date

CITY OF PARMA HEIGHTS
Code Requirements for Detached Garages
***2013 Residential Code of Ohio**

STUDS & RAFTERS

Shall have a spacing of not more than 16" o.c.

RAFTER TIES

If rafter ties are used, they are to be 2 x 4 @ 48" o.c. attached with screws or bolted.

EGRESS DOOR

Every detached garage shall be provided with an egress door. Minimum size to be 2'x6" wide, 6'x8" high and 1-3/8" thick. Door shall have a lock which is always openable from the inside without a use of a key. All hardware shall be noncorrosive metal.

FLOOR AREA

Private garages required for each 1,2, & 3 family & townhouse dwelling unit shall have a minimum of 441 sq. ft. and maximum of 750 sq. ft. The floor area for garages shall be measured from the exterior face of the enclosing walls at ground floor level. If exterior drain is used, floor should be pitched out and exterior drain must be tied into storm sewer. If interior drain is used it needs to be tied into sanitary sewer.

GUTTERS & DOWNSPOUTS All garages shall have gutters and downspouts and must be tied into existing storm sewer.

HEIGHT

No garage shall be over fifteen feet (15') high.

DEPTH

No garage shall be over 30 feet (30') in depth in a rear area.

REAR YARD LINE

Detached garages shall not be nearer than three feet (3') to its respective rear lot line.

SIDE LINE

Detached garage shall not be any closer than three feet (3') to the side line. In addition, no garage shall be closer than ten feet (10') to any other structure.

**WOOD FRAME
CONSTRUCTION**
(600 sq. ft. or less)*

Bottom of footings of frame garages 600 sq. ft or less shall not be less than 12" below finished grade, and 12" wide, 1/2" anchor bolts and washer, within 12" of corners with maximum spacing 6ft. o.c., minimum of two bolts per sill piece. Minimum of 7" embedment.

**WOOD FRAME
CONSTRUCTION**
(601 sq. ft. and over)*

Trench footing 42" below grade, 12" wide minimum.

**MASONRY
CONSTRUCTION**

Footer 42" below grade, 12" wide minimum.

GARAGE PAD

4"thick, 3,500 PSI concrete with 6 x 6, 1.4 x 1.4 welded wire mesh on 4" of porous fill.

CURBING

Curbing on garage pads will be minimum of 6" in width and 4" high.

**SIDE LINE
(main structure)**

Whenever the garage is detached from the main structure, there shall be a minimum width of nine feet (9') between home and side line of the driveway side of lot.

CORNER LOTS

Located to any adjoining lot

Side Line	Three Feet (3')
Rear Line	Three Feet (3')
Street Line	Within twenty feet (20') of any street line. In addition, no garage shall be any closer than ten feet (10') to any other structure located on any other adjoining lot irrespective of lot lines.

REQUIRED INSPECTIONS:

1. Footer inspection before pouring concrete.
2. Foundation, slab and drains before back-filling.
3. All framing (rough, final)
4. Electric (rough, final)
5. Plumbing (rough, final)
6. All final inspections.

PLANS


1. All applications to be filled out and submitted.
2. Submit 3 sets of plans including the plot plan.

RESIDENTIAL PERMIT FEES:

Building Permit Fee	\$150.00
(includes yard drain, gutters, downspouts and sewer)	
Electric Permit	\$75.00 base fee +
	\$ 2.00 for each outlet/switch
	and/or fixture
	+ 1% tax

1. Garage floor slab shall have a minimum compressive strength of 3,500 pounds per square foot with 5 to 7 percent air entrainment. Reinforced with 6 x 6 1.4 x 1.4 welded wire mesh (RCO Table R402.2).
2. Curb 6" wide x 4" high.
3. Anchors ½" diameter bolt, washer and nut 6' – o" on center, within 12" of corners, a minimum of two anchors per sill piece. Minimum embedment of 7". (Foundation anchor straps equivalent to the bolts may be used) (RCO 403.1.6).
4. Sole Plate: Treated to protect against decay per AWPA (RCO 319).
5. Studs 2 x 4 @ 16" o.c. (RCO 602).
6. Jack Studs (RCO Figure R602.3.2).
7. Header (RCO Table R502.5(1) & (2)).
8. Top Plate: Double top plate, splices offset by 24" minimum, and lapped at corners (RCOR602.3.2).
9. Wall Bracing: 1 x 4 let in, metal strap, or wall sheathing (RCO R602.10.3).
10. Ceiling rafter: Per RCO Table R802.4(1) thru R802.4(2) minimum 2 x 6.
11. Rafters: Per RCO Table R802.5.1(1).
12. Roof Sheathing: Minimum thickness 5/8" (RCO R803).
13. Roofing: Shingles and underlayment (RCO Chapter 9).
14. Siding: (RCO R703).
15. Gutters & Downspouts: Gutters and downspouts and required and are to be tied into the storm drain unless no drain is available, subject to approval of the Building Department.

BUILDING DEPT. CITY OF PARMA HEIGHTS



FOR GARAGE DRAINS OR YARD DRAINS

① SAND BACKFILL

*NOTE: PLASTIC PIPE MAY BE USED:

- PVC - SCHEDULE #30-33, OR USE PVC CEMENT
- USE ABS CEMENT

WHEN JOINING PLASTIC PIPE TO CROCK USE:

- HYDRAULIC CEMENT OR OTHER APPROVED METHODS

CITY OF PARMA HEIGHTS
BUILDING DEPARTMENT
440-884-9607

DRAIN IN DRIVEWAY REQUIREMENTS

Code allows required drain to be placed anywhere in driveway but must be tied into the storm line, usually an underground connection to a downspout of the house and therefore on to storm.

If putting drain inside garage then it must tie into the sanitary line, not the storm. Most often, this is a difficult run and connection to make. So a gentle slope of the slab out towards the overhead garage door is how it is usually handled.



RAZING APPLICATION

PERMIT# _____
PARCEL # _____
DATE: _____

FEE \$50.00

SITE OF RAZING _____

WHAT IS BEING RAZED: _____

HOMEOWNER NAME: _____

PHONE # _____

CONTRACTOR NAME: _____

ADDRESS: _____

PHONE # _____

COST OF RAZING \$ _____

SIGNATURE: _____